

**TOWN OF HARWICH**  
**Cranberry Valley Golf Course**  
**Clubhouse Entrance Site Improvements**

**Addendum #3**  
**November 16, 2020**

The attention of bidders submitting bids for the subject project:

**CRANBERRY VALLEY GOLF COURSE CLUBHOUSE ENTRANCE SITE IMPROVEMENTS**  
**INVITATION FOR BIDS (IFB)**

are called to the following addendum.

**Bidders shall confirm receipt of Addendum 3 in their bid submission.**

**1. Bid Questions & Responses:**

- Follow up question to Addendum #2, the second bullet item included in Addendum #2 calls for a minimum of 6" thick compacted gravel base for all paved areas. Should the contractor bid for a new gravel base under the existing asphalt? Or shall the contractor assume that the base is sufficient and address with a change order, if required?
  - The contractor shall assume that the thickness of gravel base material in areas of existing pavement is sufficient. Additional gravel material required within existing asphalt areas shall be addressed with a change order, if required.

**\*\*\* END OF ADDENDUM #3 \*\*\***